

CERTIFICATE OF COMPLIANCE

Certificate Number UL-CA-L21164-12531-02303002-1
Report Reference MH21164-20030320
Date 24-Feb-2023

Issued to: EMCO WHEATON RETAIL CORP
2300 INDUSTRIAL PARK DR SE WILSON, NC 27893-9316
United States

This is to certify that representative samples of EGVV7 - Tank Accessories for Flammable and Combustible Liquids Certified for Canada
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: ANSI/CAN/UL/ULC 2583:2021, 1st Ed., Issue Date: 2021-12-08

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number UL-CA-L21164-12531-02303002-1
Report Reference MH21164-20030320
Date 24-Feb-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model	Category Description
A1100 Guardian, may be followed by suffix T (Testable)	Overfill protection device, Class 1, for use with flammable and combustible liquids, in nominal pipe sizes (NPS) 4, and maximum pressure 50 kPa.

Deborah Jennings-Conner
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-2308053-0
Report Reference MH21164-20030320
Date 24-Feb-2023

Issued to: EMCO WHEATON RETAIL CORP
2300 INDUSTRIAL PARK DR SE WILSON, NC 27893-9316
United States

This is to certify that representative samples of EGVV - Tank Accessories for Flammable and Combustible Liquids
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: ANSI/CAN/UL/ULC 2583:2021, 1st Ed., Issue Date: 2021-12-08

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-2308053-0
Report Reference MH21164-20030320
Date 24-Feb-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model	Category Description
A1100 Guardian, may be followed by suffix T (Testable)	Overfill protection device, Class 1, for use with flammable and combustible liquids, in nominal pipe sizes (NPS) 4, and maximum pressure 50 kPa.

Deborah Jennings-Conner
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>