




A1004-210TEST A1004-210TEST-P

SPILL CONTAINMENT INTEGRITY TESTERS

Test any Emco Spill container for leak tightness according to Emco's TP-160 test procedure:




Found a leak? TP-160 includes steps to diagnose spill container leak issues without needing to disassemble the spill container.




A1004-210TEST-P Pressure Test Apparatus

The A1004-210TEST-P applies controlled pressure to spill containers to aid in leak diagnosis.



A1004-210TEST Vacuum Test Apparatus

The A1004-210TEST is designed to perform vacuum testing on Emco spill containment according to TP-160, spill containment integrity test procedure.



A0081 Test Cover

The A0081 Test Cover is used with the Emco A1004-210TEST to perform vacuum testing on spill containment.



569143 Test Cap

The 569143 Test Cap is used on double wall spill containers to plug the monitor tube for a vapor tight independent primary space.

Replacement Components

| Model No. | Description |
|-----------|--------------------|
| 494343 | Test Adapter |
| 569194 | Air Switch 1/8" |
| 569195 | Air Regulator 1/8" |



494343
Test Adapter

Accessory Components

| Part No. | Spill Containment | Diameter | Lbs. |
|--------------|-------------------------------|----------|------|
| A0081-12TEST | A1005-505 Series | 12.40" | 4.5 |
| A0081-13TEST | A1004-316/517 Series | 13.13" | 4.5 |
| A0081-15TEST | A1004-210 Series | 15.25" | 4.7 |
| A0081-17TEST | A1004-215 Series, A1005-505CP | 17.38" | 5.0 |
| 569143 | All Models | - | 0.5 |